CHANDRA
X-ray Center 60 Garden St., Cambridge Massachusetts 02138 USA



MEMORANDUM

August 16, 1999

From: M. Juda and A. Dobrzycki
To: Distribution
Subject: HRC Deadtime and Telemetry Saturation
File: /data/juda1/juda/asc/hrc/tex/telem_saturation.tex

1 Introduction

There are two sources of electronic deadtime within the HRC. The first is due to the time the HRC takes to process the information from an event registered by the MCP. The second is telemetry saturation; the Chandra X-ray Observatory has a limited telemetry bandwidth that results in a maximum allowed number of telemetered events per major frame (32.8 s) for the focal plane science instruments. When the HRC has the observing mode telemetry allocation (24 kbps of serial digital data), the telemetry has 378 "slots" available for event information every 2.05 s, for a mean event rate maximum of ~ 184.39 events s^{-1}. Observations of bright, diffuse sources could exceed this mean rate resulting in a deadtime as events cannot be put into the telemetry stream.

The following setion describes how the parts of the HRC hardware that perform event processing effect deadtime. Subsequent sections describe a computer simulation of the timing aspects of event processing and presents results from simulations for a range of input event rates which includes rates higher than the telemetry limit. Algorithms for determining the deadtime for rates both above and below the telemetry saturation limit are given. The final section compares the simulation results to measurements using "flight-like" electronics.

2 HRC Event Processing

When the HRC MCPs are triggered by an event, it is counted and a series of hardware checks are performed to decide whether it should be processed and telemetered to the ground; this takes $\sim 19.5\mu$s. If the event passes these checks it is counted as a valid event and the hardware processing that generates the telemetered event information is usually started. The processing will not occur if the hardware is already processing an event. From the time of the trigger to the time that the event information for telemetry has been generated is 68.5 μs. The HRC hardware is effectively "dead" to event processing during the 19.5 μs interval for the rejected events or the 68.5 μs interval for the accepted events. In simple terms these two times are the deadtime per rejected and accepted events respectively.

The HRC contains a hardware buffer that queues events for output into the telemetry slots. This "primary" science FIFO is large enough to hold the event information for 128 events. If events arrive faster than they can be telemetered, the FIFO will fill. Once it is full the hardware will hold the last event it receives, stop processing, and wait until one event has been removed from the FIFO; at this point it moves the event information it is holding into the FIFO and resumes processing. It is the fact that the hardware stops processing when the FIFO fills that creates the possibility for telemetry saturating deadtime. Even though the "valid" events are not being processed, they are still being counted.

3 Simulation Description

In an effort to understand the HRC performance at sustained rates near telemetry saturation, we have written a set of software tools that simulates the process. The simulation operates in a series of steps.

The simulation starts with the generation of event times; a Poissonian process is simulated by generating a sequence of times with an exponential distribution of times between events. The mean event rate is controlled by the mean of the exponential distribution. These event times are piped to a tool that determines where the times occur relative to the telemetry major frames and minor frames. Additional information that can be used for other simulation purposes are also generated.

The event time information is then passed on to a tool that simulates how the HRC hardware processing works. All events are assumed to have passed the hardware tests, i.e. they are considered to be "valid" events. An event time is compared to the previous time to see if it arrived while the hardware was processing that event; if so it is counted as a piled-up event and not put into the FIFO storage space. If the event wasn't piled-up, the event time is compared to the current telemetry time to see if events should be taken from the FIFO.

If the time of the next telemetry slot occurs before the event time the event information is taken from the FIFO storage space and the major frame, minor frame, and event slot within the minor frame in which the event is telemetered is added to it. This process is repeated as many times as necessary, either the time of the slot is after the event time or there are no more events in the FIFO storage space.

If the time of the next telemetry slot is after the event time, the FIFO is checked to see if there is room for an event; if there is the event timing information is put into the FIFO storage space. If the FIFO is full, the event is not put into the FIFO storage space. The time from when the FIFO fills to when the next set of event information is transfered from the FIFO storage space to a telemetry slot is accumulated. At the end of the simulation the total time spent with the FIFO full is reported along with the total number of events input, the number of telemetered events, the number of piled-up events, and the number of events that occurred while the FIFO was full.

4 Simulation Results

Simulator runs where performed for a range of mean event rates up to 1050 events s^{-1}. Each simulation was run for an exposure of 1000 s. Table 1 contains the summary results from several simulation runs. As expected, the time spent with the FIFO full is zero until the mean rate is higher than the telemetry saturation rate. For rates above the telemetry saturation rate the deadtime increases rapidly with event rate. The deadtime fraction is plotted as a function of mean input rate in Figure **??**.

In addition to the information from the events, the HRC telemeters the total event rate (total triggers of the MCP in 1 s intervals) and the valid event rate (those triggers that pass the hardware tests). We can use these to derive the instrument deadtime.

At rates below telemetry saturation, the deadtime t_d for a selected interval is given by:

$$t_d = t_1 N_{total}(1 - \frac{N_{valid} - N_{telem}}{N_{valid}}) + t_2 N_{telem}, \tag{1}$$

where t_1 is the time for the hardware checks (19.5 μs), t_2 is the time to complete the event information processing (49 μs), N_{total} is the number of events that triggered the MCPs, N_{valid} is the number of events that passed the hardware tests, and N_{telem} is the number of events that was telemetered.

At rates above telemetry saturation a simple approximation to the deadtime is given by

$$t_d = T \frac{N_{valid} - N_{telem}}{N_{valid}} \tag{2}$$

Table 1: Telemetry Saturation Simulations — 1000 s exposures

	Number of Events				Time
Mean Rate	Total Valid	Telemetered	Piled-up	FIFO-full	FIFO-Full
10	10016	10007	9	0	0.000
100	100090	99422	668	0	0.000
150	150250	148721	1529	0	0.000
180	180233	177996	2237	0	0.000
185	185284	182857	2365	62	0.403
190	190312	184493	2501	3318	18.065
195	195317	184489	2636	8192	43.714
200	200346	184514	2788	13044	67.718
210	210412	184511	3090	22811	112.388
220	220362	184515	3385	32462	152.731
230	230257	184514	3694	42049	188.999
240	240361	184511	4030	51820	223.909
250	250327	184515	4354	61458	254.340
260	260596	184515	4679	71402	283.804
270	270627	184516	5062	81049	311.018
280	280634	184516	5413	90705	336.072
290	290517	184515	5795	100207	358.590
300	300579	184516	6195	109868	381.057
350	349832	184517	8333	156982	466.721997
400	399440	184516	10793	204131	535.607309
450	449640	184516	13551	251573	586.421435
505	504242	184517	16973	302752	632.676754
600	599854	184517	23961	391376	690.467608
740	739840	184517	36493	518830	748.298812
800	799881	184517	42688	572676	768.222602
1000	1000362	184517	66294	749551	815.157201
1050	1050192	184517	72955	792720	823.445800

where T is the duration of the interval. Note that this is just the fraction of the events that were acceptable for processing and inclusion in telemetry but which didn't make it. This approximation is plotted as a dashed line in figure 1; it provides a reasonably close match ($< 2\%$ different) to the simulation result near the point of telemetry saturation.

5 Comparison to Measurements

In order to demonstrate the validity of the model, a set of data were taken in the HRC laboratory using "flight-like" HRC electronics, a remote command and telemetry unit (RCTU), a command and telemetry unit emulator (CTUE), and an HRC EGSE computer. A random pulse generator was used to stimulate the inputs to the MCP-trigger and a set of crossed-grid charge detector pre-amplifiers of the HRC electronics. These random pulses were also counted on a scaler. Data collection runs were performed for 100 s each, with the mean input event rate adjusted from run to run; mean rates from ~ 50 pulses s^{-1} to ~ 1000 pulses s^{-1} were used. For each run, the intervals of telemetry collection and scaler counting were started nearly simultaneously.

Table **??** gives the results of these data collections. The "root name" of each telemetry data set is given; these names give the date-time stamp of the start of the data collection. The average input event rate is determined from the total number of events counted by the scaler in the 100 s interval; the statistical uncertainty is given. The average total and valid event rates are the means of the values of the samples in the telemetry file for the given run; the uncertainty is the standard deviation of the samples. The average telemetered event rate is given by the total number of events in the telemetry file for the given run divided time duration of the telemetry. The time duration of the telemetry file is given by the number of minor frames that it contains times the duration of a minor frame (0.25625 s). The uncertainty on the telemetered event rate is solely statistical.

As expected, the telemetered event rate saturates at ~ 184.4 events s^{-1} as the input rate rises above this level. Figure **??** shows the deadtime fraction calculated from the data in table **??** using the algorithms given in section 4; the plotted curve is the deadtime fraction given by simulation runs. The deadtime corrected rates are in included in table **??**. The deadtime corrected rates are in good agreement with the input rates below the telemetry saturation point (184.4 events s^{-1}) and in reasonable agreement, systematically low by less than 2%, for input rates up to 5 times the telemetry saturating rate.



Figure 1: Deadtime fraction as a function of mean input event rate. The solid line is the result of the simulations. The dashed line is an approximation given by the fraction of the total number input that were not telemetered.



Figure 2: Comparison of simulations to data. Boxes give the calculated deadtime fraction for the laboratory measurements at each of the input rates. The solid line is the deadtime fraction determined from simulations.

Table 2: Event Rate Comparisons — 100 s exposures

	Average Event Rates (counts s^{-1})				
Data Set	Input	Total	Valid	Telemetered	DT Corrected
1999167.134447	51.57±0.72	51.34±3.98	51.34±3.98	51.40± 0.73	51.58
1999167.134819	107.72±1.04	107.56±4.74	107.56±4.74	107.17±1.05	108.00
1999167.135106	164.23±1.28	163.78±4.98	163.78±4.98	162.65±1.31	164.5
1999167.135417	177.08±1.33	176.28±4.69	176.28±4.69	175.31±1.34	177.4
1999167.135736	184.25±1.36	184.17±5.28	184.16±5.28	182.44±1.39	184.7
1999167.140029	200.09±1.41	199.15±4.61	199.15±4.61	184.38±1.38	199.2
1999167.140357	217.85±1.48	217.30±6.08	217.30±6.08	184.47±1.43	217.3
1999167.140648	250.02±1.58	249.48±5.46	249.48±5.46	184.42±1.38	249.5
1999167.140946	295.34±1.72	293.62±5.81	293.62±5.81	184.40±1.45	293.6
1999167.141241	505.38±2.25	501.89±6.09	501.88±6.07	184.38±1.41	501.9
1999167.141529	739.13±2.72	730.64±6.48	730.64±6.48	184.47±1.43	730.6
1999167.141824	1026.02±3.20	1008.76±7.68	1008.76±7.68	184.36±1.39	1009.00